

MEMBRANE
EXTENDED BELOW
NAILER AND SECURED

EXISTING OR NEW METAL
COPING CAP

SLOPE

8" MINIMUM
FLASHING HEIGHT

LIQUID APPLIED TOP COAT

LIQUID APPLIED FULLY REINFORCED
FLASHING (CAN BE APPLIED BEFORE
OR AFTER LEVELING COAT)

LIQUID APPLIED BASE COAT

LIQUID APPLIED LEVELING COAT

EXISTING ROOF MEMBRANE
AND FLASHINGS (GRAVEL
NOT SHOWN FOR CLARITY)

EXISTING INSULATION

NOTES

1. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.
3. THE EXISTING LOOSE GRAVEL MUST BE REMOVED AND THE ROOF MUST BE REPAIRED PER MANUFACTURER REQUIREMENTS PRIOR TO APPLICATION OF THE LEVELING COAT.



SHEET TITLE:
BASE FLASHING AT PARAPET
WALL WITH METAL COPING
GRAVEL BUR RESTORATION

SCALE:
NTS

DRAWING No.:
DWG NO. LA-GR-01