



**NOTES**

1. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.
3. THE EXISTING LOOSE GRAVEL MUST BE REMOVED AND THE ROOF MUST BE REPAIRED PER MANUFACTURER REQUIREMENTS PRIOR TO APPLICATION OF THE LEVELING COAT.



SHEET TITLE:  
**BASE FLASHING AT MEMBRANE COATED  
 SHEET METAL HOOD FOR PIPING THROUGH  
 ROOF DECK GRAVEL BUR RESTORATION**

SCALE:  
**NTS**

DRAWING No.:  
**DWG NO. LA-GR-16**