



FLEXIBLE LINER WITH COMPRESSIBLE INSULATION

2 X 6 MIN. WOOD NAILER ATTACHED TO SUBSTRATE — OVERALL THICKNESS TO MATCH INSULATION

NOTES

1. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.
3. THE EXISTING LOOSE GRAVEL MUST BE REMOVED AND THE ROOF MUST BE REPAIRED PER MANUFACTURER REQUIREMENTS PRIOR TO APPLICATION OF THE LEVELING COAT.



SHEET TITLE:
**BASE FLASHING AT ROOF TO
 WALL EXPANSION JOINT
 GRAVEL BUR RESTORATION**

SCALE:
 NTS

DRAWING No.:
DWG NO. LA-GR-07