



EXISTING FLASHINGS  
OVER AREA DIVIDER

8" MINIMUM  
FLASHING HEIGHT

EXISTING OR NEW  
SHEET-METAL COVER—  
MAY NEED TO BE REMOVED  
FOR FLUID APPLIED SYSTEM  
INSTALLATION

LIQUID APPLIED TOP COAT

LIQUID APPLIED  
REINFORCED BASE COAT

EXISTING ROOF MEMBRANE  
AND FLASHINGS

EXISTING INSULATION

**NOTES**

1. AN AREA DIVIDER SHOULD NEVER RESTRICT THE FLOW OF WATER.
2. FLASHING REQUIREMENTS ARE TYPICAL FOR BOTH SIDES OF THE AREA DIVIDER.
3. PRIMING OF THE SUBSTRATE MAY BE REQUIRED / SPECIFICATIONS AND M
4. REINFORCEMENT MUST BE FULLY SATURATED O

SHEET TITLE:  
BASE FLASHING  
ENCLOSURE FOR  
RIBBED IN OF DECK



SHEET TITLE:  
**BASE FLASHING AT AREA DIVIDER  
IN ROOF SUSTEM FULLY  
REINFORCED RESTORATION**

SCALE:  
NTS  
DRAWING No.:  
**DWG NO. LA-FR-09**