



NOTES

1. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.
3. CANT STRIP IS OPTIONAL



SHEET TITLE:
 BASE FLASHING AT HSS STRUCTURAL
 BEAM THROUGH ROOF DECK FULLY
 REINFORCED RESTORATION

SCALE:
 NTS

DRAWING No.:
 DWG NO. LA-LR-32