



FLEXIBLE LINER WITH
COMPRESSIBLE INSULATION

2 X 6 MIN. WOOD NAILER
ATTACHED TO SUBSTRATE—
OVERALL THICKNESS TO MATCH
INSULATION

NOTES

1. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.



SHEET TITLE:
**BASE FLASHING AT ROOF-TO-WALL
 EXPANSION JOINT FULLY
 REINFORCED RESTORATION**

SCALE:
 NTS
 DRAWING No.:
DWG NO. LA-LR-07