

NOTES

- PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
- 2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.
- 3. WHERE THE SHEET-METAL ENCLOSURE OVERLAPS THE BASE FLASHING AT LEAST 3 INCHES, THE REMOVABLE SHEET-METAL COUNTER FLASHING IS NOT REQUIRED.



SHEET TITLE:
BASE FLASHING AT SHEET-METAL
ENCLOSURE FOR PIPING THROUGH
ROOF DECK PLUS SYSTEM

SCALE:

NTS

DRAWING No.:

DWG NO. LA-LR-15