



**NOTES**

1. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.



SHEET TITLE:  
**EMBEDDED EDGE-METAL FLASHING  
 [GRAVEL STOP] FULLY REINFORCED  
 RESTORATION**

SCALE: **NTS**  
 DRAWING No.: **DWG NO. LA-FR-03**