

NOTES

- 1. WHERE THE SKYLIGHT, SCUTTLE OR SMOKE VENT FRAME OVERLAPS THE BASE FLASHING AT LEAST 3 INCHES, THE REMOVABLE SHEET-METAL COUNTERFLASHING IS NOT REQUIRED.
- 2. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.



BASE FLASHING AT PREFABRICATED

METAL CURB PARTIALLY

REINFORCED RESTORATION

SCALE:

NTS

DRAWING No.:

DWG NO. LA-PR-12