



NOTES

1. CONDUCTOR HEAD TO BE 1 INCH MINIMUM BELOW BOTTOM OF THROUGH-WALL SCUPPER.
2. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.



SHEET TITLE:
**BASE FLASHING AT THROUGH-WALL
 SCUPPER PARTIALLY REINFORCED
 RESTORATION**

SCALE:
 NTS
 DRAWING No.:
DWG NO. LA-PR-25