

NOTES

- 1. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
- 2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.
- 3. FLASHING REQUIREMENTS ARE TYPICAL FOR BOTH SIDES OF THE EXPANSION JOINT.



SHEET TITLE:

BASE FLASHING AT EXPANSION JOINT WITH METAL COVER LIQUID APPLIED PLUS SYSTEM SCALE:

NTS

DRAWING No.:

DWG NO. LA-PR-08