

MEMBRANE OR FLUID APPLIED SYSTEM EXTENDED BELOW NAILER AND SECURED

EXISTING OR NEW METAL COPING CAP

SLOPE

OPTIONAL FLASHING BASE PLY, CANT MAY BE REQUIRED

TOP COAT

FULLY REINFORCED BASE COAT

8" MINIMUM FLASHING HEIGHT

NEW BASE PLY INSTALLED ACCORDING TO SPECIFICATIONS

NEW INSULATION AND COVERBOARD

NOTES

1. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.