

## **NOTES**

- PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
- REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.
- 3. WHERE THE SHEET-METAL ENCLOSURE OVERLAPS THE BASE FLASHING AT LEAST 3 INCHES, THE REMOVABLE SHEET-METAL COUNTER FLASHING IS NOT REQUIRED.



SHEET TITLE:

BASE FLASHING AT SHEET METAL ENCLOSURE FOR PIPING THROUGH ROOF DRAWING No.: DECK LIQUID APPLIED PLUS SYSTEM

SCALE:

NTS

DWG NO. LA-PR-15