



NOTES

1. PRIMING OF THE SUBSTRATE MAY BE REQUIRED, FOLLOW SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS.
2. REINFORCEMENT MUST BE FULLY SATURATED OR ENCAPSULATED IN BASE COAT AS DESCRIBED IN SPECIFICATIONS.



SHEET TITLE:

EQUIPMENT SUPPORT STAND LEG
LIQUID APPLIED PLUS SYSTEM

SCALE:

NTS

DRAWING No.:

DWG NO. LA-PR-11