



LIGHTNING ROD BASE, SET IN APPROVED SEALANT

2" X 6" MEMBRANE STRIP, HEAT WELDED TO FIELD MEMBRANE 4" ON EITHER SIDE OF BASE. INSTALL ADDITIONAL MEMBRANE STRIPS AT 48" O.C. TO NEXT TERMINAL.



SHEET TITLE:
LIGHTNING PROTECTION

SCALE:
NTS
DRAWING No.:
DWG NO. 62