



PENETRATION (CLEANED AND PRIMED)

APPLY CONVEX TOOLED BEAD OF TREMPRO PLUS SEALANT TO CLEAN AND PRIMED SURFACE

2-PIECE METAL RAIN HOOD (OPTIONAL)

APPROVED SELF LEVELING 1-PART URETHANE

APPROVED METAL PITCH PAN, FASTEN WITH GALVANIZED ANNULAR RING SHANK NAILS (3" O.C.) (PRIME INTERIOR SIDE OF PITCH PAN AND PENETRATION)

TREMPRO KEE MEMBRANE FLASHING STRIP, HEAT WELDED

TREMPRO KEE NON-REINFORCED AT CORNERS, HEAT WELDED

TREMPRO KEE MEMBRANE

BOND-BREAKER

NON-SHRINK GROUT

FILL VOIDS W/COMPRESSIBLE FILLER AND INSULATION AS REQUIRED

WOOD BLOCKING ATTACHED @ 250 LBF/FT

INSULATION ATTACHED PER SPECIFICATION REQUIREMENTS



SHEET TITLE:

PITCH PAN FLASHING

SCALE:

NTS

DRAWING No.:

DWG NO. 74