



NOTES

1. CLEAN METAL AND MEMBRANE WITH TPO SEAM CLEANER AND ALLOW TO DRY BEFORE PRIMING
2. TPO COVER IS ONLY TO BE USED WITH TPO MEMBRANE SYSTEMS ONLY.
3. FOR INSULATION THICKNESS GREATER THAN 6" (203 mm). A HARD BOARD IS REQUIRED ON MECHANICALLY FASTENED SYSTEMS.
4. APPROVED CAULK GRADE SEALANT SHOULD BE FEATHERED OUT; ENSURE PRIMER EXTENDS UNDER APPROVED CAULK GRADE SEALANT.
5. WHEN ROOF SLOPE IS GREATER THAN 1:12 IN CLIMATES WITH SNOW AND ICE REFER TO ALTERNATE EDGE DETAIL.
6. THIS DETAIL IS NOT TO BE USED ON SLOPES GREATER THAN 1:12.



SHEET TITLE:

COVER TAPE OVERLAP AT
ROOF EDGE DETAIL

SCALE:

NTS

DRAWING No.:

DWG NO. 21