



24 GAUGE CONTINUOUS HOOK STRIP
SECURED WITH APPROVED
FASTENERS @ 12" (305 mm) O.C.

24 GAUGE METAL EDGE

RING SHANK GALVANIZED NAIL @ 4"
(102 mm) O.C. STAGGERED OR APPROVED
SCREWS 12" (305 mm) O.C. AND 2" (52 mm)
MINIMUM FROM OUTSIDE EDGE OF METAL.

WOOD NAILER, 5/4" (31.8 mm) x 4" (102 mm)
MIN SECURED TO DECK

CONTINUOUS BEAD OF APPROVED CAULK
GRADE SEALANT OR TPO CUT EDGE
SEALANT

TPO COVER TAPE

PRIME SURFACE UNDER TAPE
WITH TPO PRIMER

REINFORCED TPO MEMBRANE
(PERIMETER SHEET IF REQUIRED)

APPROVED ROOF INSULATION

ROOF DECK/SUBSTRATE

NOTES

1. CLEAN METAL AND MEMBRANE WITH TPO SEAM CLEANER AND ALLOW TO DRY BEFORE PRIMING.
2. TPO COVER TAPE ONLY TO BE USED WITH TPO MEMBRANE SYSTEMS.
3. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICAL SYSTEMS ONLY.
4. APPROVED CAULK GRADE SEALANT SHOULD BE FEATHERED OUT. ENSURE PRIMER EXTENDS UNDER APPROVED CAULK GRADE SEALANT.
5. THIS DETAIL IS **NOT** TO BE USED ON SLOPES GREATER THAN 1:12.



SHEET TITLE:
COVER TAPE AT ROOF EDGE DETAIL

SCALE:
NTS

DRAWING No.:
DWG NO. 17