



NOTES

1. ADD BALLAST PER SPECIFICATION FOR BALLASTED SYSTEMS.
2. GUTTER IS OPTIONAL.
3. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICALLY FASTENED SYSTEMS ONLY.