



NOTES

1. WIDTH OF PERIMETER TREATMENT (A OR B) SHALL BE 10% OF THE BUILDING'S NARROWEST WIDTH (W) OR 40% OF THE BUILDING EAVE HEIGHT (H), WHICHEVER IS LESS, WITH 4' (1.22 m) BEING THE MIN. FOR TREMCO STANDARD REQUIREMENTS. SEE HALF-SHEET REQUIREMENTS IN THE MECHANICALLY ATTACHED SECTION.
2. FOR ADHERED, SELF-ADHERED, AND ISO-WELD SYSTEMS, SEE INSULATION TABLE FOR ENHANCEMENTS.



SHEET TITLE:

ROOF AREA ZONE LAYOUT DETAIL

SCALE:

NTS

DRAWING No.:

DWG NO. 67