



NOTES

1. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICALLY FASTENED SYSTEMS ONLY.
2. WALKWAY PAD OR PAVER WITH SLIP SHEET REQUIRED AT ALL ROOF ACCESS POINTS. FOR BALLASTED ATTACHED SYSTEMS PAVER IN LIEU OF PAD AND BALLAST PER SPEC.
3. APPLY TPO CUT EDGE SEALANT TO ALL CUT REINFORCED TPO EDGES.



SHEET TITLE:

THRESHOLD FLASHING DETAIL

SCALE:

NTS

DRAWING No.:

DWG NO. 88