



NOTES

1. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICALLY FASTENED SYSTEMS ONLY.
2. EDGE OF MEMBRANE SHOULD NOT TERMINATE BELOW GUTTER EDGES.
3. APPLY TPO CUT EDGE SEALANT TO ALL CUT REINFORCED TPO EDGES



SHEET TITLE:
**TREMPLY TPO BAR -
 NEW INSTALLATION**

SCALE:
NTS

DRAWING No.:
DWG NO. 91