



NOTES

1. 1. TERMINATION BAR MUST BE FASTENED 6" (152 mm) O.C. FOR THIS DETAIL.
2. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICALLY FASTENED SYSTEMS ONLY.
3. APPLY TPO CUT EDGE SEALANT TO ALL CUT REINFORCED TPO EDGES



SHEET TITLE:
**TREMPLY TPO TERMINATION
 BAR ROOF EDGE DETAIL**

SCALE:
NTS

DRAWING No.:
DWG NO. 97