



TPO COATED METAL EDGING WITH HEMMED EDGE

HEAT-WELDED LAP

APPROVED FASTENERS @ 12" (305 mm) O.C.

REINFORCED TPO MEMBRANE (PERIMETER SHEET IF REQUIRED)

APPROVED ROOF INSULATION

ROOF DECK/SUBSTRATE

WOOD NAILER 5/4" (38.1 mm) x 4" (102 mm) MIN. SECURED TO DECK (OPTIONAL)

## NOTES

1. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICAL SYSTEMS ONLY.
2. APPLY TPO CUT EDGE SEALANT TO ALL CUT REINFORCED TPO EDGES



SHEET TITLE:  
**VERTICAL WALL EDGE TERMINATION  
 WITH COATED METAL DETAIL**

SCALE:  
**NTS**

DRAWING No.:  
**DWG NO. 99**